

Preventative Maintenance Kits & Spare Parts



972 Centerville Road,
Pulaski, New York 13142
(315) 298-5121

ENDURA® SOLA HYDRONIC CONDENSING BOILERS

ENDURA



A consistent preventative maintenance routine is an important part of continuing efficient and reliable operation of your hydronic boiler system. This bulletin details the recommended parts to perform an annual PM of your Fulton boiler(s) along with suggested spare parts to have on hand if the need arises.

Preventative Maintenance of your Fulton boiler should be performed by a factory authorized Service Technician in accordance with the Installation, Operation and Maintenance Manual.

PREVENTATIVE MAINTENANCE KIT	PART #
EDR-0750/1000 with SOLA Controls Annual PM Kit	4-50-071000
KIT INCLUDES:	
Endura Ignition Gasket	2-12-001261
Burner Gasket (Qty: 2)	2-12-001270
Combustion Air Filter	2-30-071039
Ignition Assembly with Igniter Bridge	2-20-000135
O-Ring Gasket for Burner Elbow	2-12-000236

PREVENTATIVE MAINTENANCE KIT	PART #
EDR-1500/2000 with SOLA Controls Annual PM Kit (Metal Mesh Burner)	4-50-072001
KIT INCLUDES:	
Endura Ignition Gasket	2-12-001261
Burner Gasket (Qty: 2)	2-12-001260
Ignition Assembly with Igniter Bridge	2-20-072000
Combustion Air Filter	2-30-000739
O-Ring Gasket for Burner Elbow	2-12-000235

PREVENTATIVE MAINTENANCE KIT	PART #
EDR-1500/2000 with SOLA Controls Annual PM Kit (Ceramic Mesh Burner)	4-50-072000
KIT INCLUDES:	
Endura Ignition Gasket	2-12-001261
Burner Gasket (Qty: 2)	2-12-001260
Combustion Air Filter	2-30-000739
Ignition Assembly with Igniter Bridge	2-20-000135
O-Ring Gasket for Burner Elbow	2-12-000235

Spare parts listed on next page.

ENDURA

SPARE PARTS	PART #
Ignition Transformer	2-40-000976
Ignition Cable Assembly	5-11-000018
Low Water Probe	2-20-000023
6" Gas Filter Assembly Kit (EDR-750/1000)	2-30-005164
7" Gas Filter Assembly Kit (EDR-1500/2000)	2-30-005165
Gas Valve (EDR-750/1000)	2-30-005067
Gas Valve (EDR-1500/2000)	2-30-005079
Combustion Blower Assembly (EDR-750/1000)	2-30-001696
Combustion Blower Assembly (EDR-1500/2000)	2-30-001646
Replacement Silicone for Combustion Air Blower Motor	2-60-000254
SOLA Display Module	2-40-000932
SOLA Controller Base	2-40-000907
UV Scanner	2-40-000161
Temperature Sensor	2-40-000333
Air Pressure Switch	2-30-005098
Low Water Cut Off (LWCO) Relay	2-40-000421
Control Relay (120VAC)	2-40-000131
Low Gas Pressure Switch	2-30-005085
High Gas Pressure Switch	2-30-005084
SOLA Display	2-40-000932
SOLA Base	2-40-000907
Pipe Thread Sealant - 16 oz (recommended for burner removal)	2-12-000484



972 Centerville Road
 Pulaski, New York 13142
 (315) 298-5121



Find your solution at:
www.fulton.com