

Preventative Maintenance Kits & Spare Parts



972 Centerville Road,
Pulaski, New York 13142
(315) 298-5121

CLASSIC ICS 20-30 VERTICAL TUBELESS BOILERS

Classic™



PREVENTATIVE MAINTENANCE KIT	PART #
20-30HP ICS Annual Parts Kit (Pre 2007)	
KIT INCLUDES:	
Gasket Kit	4-12-000506
Probe Kit	4-30-000052
Gas Igniter	2-20-000019
Oil Igniter	2-20-000021
Gauge Glass (Clear Line) - 9¼"	2-12-000007
Gauge Glass (Red Line) - 9¼"	2-12-000017

PREVENTATIVE MAINTENANCE KIT	PART #
20-30HP ICS Annual Parts Kit (Post 2007)	
KIT INCLUDES:	
Gasket Kit	4-12-000506
Probe Kit	4-30-000052
Gas Igniter	2-20-000019
Oil Igniter	2-20-000021
Gauge Glass - 9¾"	2-12-000185

Spare parts listed on next page.

A consistent preventative maintenance routine is an important part of continuing efficient and reliable operation of your steam boiler system. This bulletin details the recommended parts to perform an annual PM of your Fulton boiler(s) along with suggested spare parts to have on hand if the need arises.

Preventative Maintenance of your Fulton boiler should be performed by a factory authorized Service Technician in accordance with the Installation, Operation and Maintenance Manual.

Classic™

SPARE PARTS	PART #
Complete Gasket Kit	4-12-000506
Ignition Electrode	2-20-000019
Blower Motor	2-40-000771
Feed Water Relay	2-40-000420
Low Water Relay	2-40-000421
Flame Control	2-40-000264
Mini Peeper UV Scanner (Honeywell)	2-40-000161
UV Scanner (Siemens)	2-40-000273
Motor Starter Relay	2-40-000200
Purge Timer	2-40-000266
Gauge Glass	2-12-000017
Gauge Glass Valves	2-30-000149
Safety Valve	2-30-000078
Complete Probe Set	4-30-000052
Air Switch	2-30-000270
High Limit Pressure Switch	2-40-003040
Operating Pressure Switch	2-40-003043
Modulation Control	2-40-000226



972 Centerville Road
Pulaski, New York 13142
(315) 298-5121



Find your solution at:
www.fulton.com

FSS-ICS-20-30-PM-KIT-220804