

Preventative Maintenance Kits & Spare Parts



972 Centerville Road,
Pulaski, New York 13142
(315) 298-5121

CLASSIC ICS 40-60 VERTICAL TUBELESS BOILERS

Classic™



PREVENTATIVE MAINTENANCE KIT	PART #
40-60HP ICS Annual Parts Kit (Pre 2007)	
KIT INCLUDES:	
Gasket Kit	4-12-000512
Probe Kit	4-30-000052
Gas Igniter	2-20-000019
Oil Igniter	2-20-000021
Gauge Glass (Clear Line) - 9¼"	2-12-000007
Gauge Glass (Red Line) - 9¼"	2-12-000017

PREVENTATIVE MAINTENANCE KIT	PART #
40-60HP ICS Annual Parts Kit (Post 2007)	
KIT INCLUDES:	
Gasket Kit	4-12-000512
Probe Kit	4-30-000052
Gas Igniter	2-20-000019
Oil Igniter	2-20-000021
Gauge Glass - 9¾"	2-12-000185

Spare parts listed on next page.

A consistent preventative maintenance routine is an important part of continuing efficient and reliable operation of your steam boiler system. This bulletin details the recommended parts to perform an annual PM of your Fulton boiler(s) along with suggested spare parts to have on hand if the need arises.

Preventative Maintenance of your Fulton boiler should be performed by a factory authorized Service Technician in accordance with the Installation, Operation and Maintenance Manual.

Classic™

SPARE PARTS	PART #
Low Water Relay	2-40-000421
Ignition Transformer	2-40-000082
LMV3 Linkageless Combustion Control	2-40-000471
AZL Display	2-40-000473
UV Scanner	2-40-000475
Air/Gas Servo	2-40-000472
Blower Motor Contactor	2-40-000878
Thermal Overload	2-40-000573
Stepdown Transformer	2-40-000440
7.5 Amp Fuse	2-45-000387
UT-32 A Process Controller	2-40-000863
High Limit Pressure Switch	2-40-003040
Operating Pressure Switch	2-40-003043
Pressure Transducer	2-40-000999
Feed Water Relay	2-40-000420
High Water Relay	2-40-000421
Safety Valve	2-30-000076
Pressure Gauge	2-30-000174
Complete Probe Set	4-30-000052
Ignition Electrode	2-20-000019
Complete Gasket Kit	4-12-000512



972 Centerville Road
Pulaski, New York 13142
(315) 298-5121



Find your solution at:
www.fulton.com

FSS-ICS-49-60-PM-KIT-220804