

Preventative Maintenance Kits & Spare Parts



972 Centerville Road,
Pulaski, New York 13142
(315) 298-5121

VMP 40-60 VERTICAL MULTI-PORT STEAM BOILERS



| PREVENTATIVE MAINTENANCE KIT | PART # |
|---|-------------|
| 40-60HP VMP Annual Parts Kit (Pre 2007) | |
| KIT INCLUDES: | |
| Gasket Kit | 4-12-000516 |
| Probe Kit | 4-30-000062 |
| Fulton Burner Igniter | 2-20-000033 |
| Webster Burner (Gas) Igniter | 2-40-005026 |
| Webster Burner (Oil) Igniter | 2-40-005025 |
| Gauge Glass (Clear Line) - 9¼" | 2-12-000007 |
| Gauge Glass (Red Line) - 9¼" | 2-12-000017 |

| PREVENTATIVE MAINTENANCE KIT | PART # |
|--|-------------|
| 40-60HP VMP Annual Parts Kit (Post 2007) | |
| KIT INCLUDES: | |
| Gasket Kit | 4-12-000516 |
| Probe Kit | 4-30-000062 |
| Fulton Burner Igniter | 2-20-000033 |
| Webster Burner (Gas) Igniter | 2-40-005026 |
| Webster Burner (Oil) Igniter | 2-40-005025 |
| Gauge Glass - 9⅝" | 2-12-000185 |

Spare parts listed on next page.

A consistent preventative maintenance routine is an important part of continuing efficient and reliable operation of your steam boiler system. This bulletin details the recommended parts to perform an annual PM of your Fulton boiler(s) along with suggested spare parts to have on hand if the need arises.

Preventative Maintenance of your Fulton boiler should be performed by a factory authorized Service Technician in accordance with the Installation, Operation and Maintenance Manual.





| SPARE PARTS | PART # |
|----------------------------|---------------|
| Gasket Kit | 4-12-000516 |
| Complete Probe Set | 4-30-000062 |
| Gauge Glass | 2-12-000185 |
| Gauge Glass Valve Set | 2-30-000255 |
| Safety Valve | 2-30-000070 |
| Air Switch | 2-30-000260 |
| Ignition Transformer | 2-40-000082 |
| Flame Programmer | 2-40-000319 |
| Low Water Relay | 2-40-000421 |
| Air/Gas Servo Motor | 2-40-000433 |
| UV Scanner | 2-40-000465 |
| AZL Display | 2-40-000437 |
| Motor Contactor | 2-40-000567 |
| Motor Thermal Overload | 2-40-000573 |
| UT-32 A Process Controller | 2-40-000863 |
| Pressure Transducer | 2-40-000994 |
| High Limit Pressure Switch | 2-40-003040 |
| Operating Pressure Switch | 2-40-003043 |
| Ignition Electrode | 2-20-000033 |



972 Centerville Road
Pulaski, New York 13142
(315) 298-5121



Find your solution at:
www.fulton.com