

# Preventative Maintenance Kits & Spare Parts



972 Centerville Road,  
Pulaski, New York 13142  
(315) 298-5121

## VMP 80-150 VERTICAL MULTI-PORT STEAM BOILERS



PREVENTATIVE MAINTENANCE KIT	PART #
80-150HP VMP Annual Parts Kit (Pre 2007)	
<b>KIT INCLUDES:</b>	
Gasket Kit	4-12-000520
Probe Kit	4-30-000062
Fulton Burner Igniter	2-20-000033
Webster Burner (Gas) Igniter	2-40-005026
Webster Burner (Oil) Igniter	2-40-005025
Gauge Glass (Clear Line) - 9¼"	2-12-000007
Gauge Glass (Red Line) - 9¼"	2-12-000017

PREVENTATIVE MAINTENANCE KIT	PART #
80-150HP VMP Annual Parts Kit (Post 2007)	
<b>KIT INCLUDES:</b>	
Gasket Kit	4-12-000520
Probe Kit	4-30-000062
Fulton Burner Igniter	2-20-000033
Webster Burner (Gas) Igniter	2-40-005026
Webster Burner (Oil) Igniter	2-40-005025
Gauge Glass - 9⅝"	2-12-000185

Spare parts listed on next page.

A consistent preventative maintenance routine is an important part of continuing efficient and reliable operation of your steam boiler system. This bulletin details the recommended parts to perform an annual PM of your Fulton boiler(s) along with suggested spare parts to have on hand if the need arises.

Preventative Maintenance of your Fulton boiler should be performed by a factory authorized Service Technician in accordance with the Installation, Operation and Maintenance Manual.





<b>SPARE PARTS</b>	<b>PART #</b>
Complete Gasket Kit	4-12-000520
Complete Probe Set	4-30-000062
Safety Relief Valve	2-30-000089
Gauge Glass	2-12-000185
Blower Motor Contactor	2-40-000643
Motor Thermal Overload	2-40-000651
Stepdown Transformer	2-40-000442
Low Water Relay	2-40-000421
Feed Water Relay	2-40-000420
High Limit Pressure Switch	2-40-003040
Operating Pressure Switch	2-40-003043
Ignition Transformer	2-40-000082
UV Scanner	2-40-000161
Flame Control	2-40-000264
Flame Amplifier	2-40-000273
Purge Card	2-40-000266
Mod Motor	2-40-000448
Gauge Glass Valve Set	2-30-000255



972 Centerville Road  
Pulaski, New York 13142  
(315) 298-5121



Find your solution at:  
[www.fulton.com](http://www.fulton.com)